

CITY OF TUCSON
DEPARTMENT OF PROCUREMENT

INVITATION FOR BID NO.100376

**ARRA TUCSON HOUSE & CRAYCROFT TOWERS TOWER FILL
AND CHILLER REPLACEMENT**

AMENDMENT NO. TWO (2)

DATE ISSUED: January 29, 2010

The referenced document has been modified as per the attached Amendment No. TWO (2).

Please sign this Amendment where designated and return the executed copy with your BID. This amendment is hereby made part of the referenced solicitation as though fully set forth therein. Any questions regarding this amendment should be addressed to **CHERIE ODESKI, SENIOR CONTRACT OFFICER** at (520) 837-4126. Cherie.Odeski@tucsonaz.gov

INVITATION FOR BID AMENDMENT

CITY OF TUCSON DEPARTMENT OF PROCUREMENT
255 W. ALAMEDA, 6TH FLOOR, TUCSON, AZ 85701
P.O. BOX 27210, TUCSON, AZ 85726
(520) 837-4126
ISSUE DATE: January 29, 2010

IFB NO.: 100376
IFB AMENDMENT NO.: Two (2)
PAGE 1 OF 2
IFB DUE DATE: 2/9/2010
CONTRACT OFFICER: Cherie Odeski W

A SIGNED COPY OF THIS AMENDMENT MUST BE SUBMITTED WITH YOUR BID.
THIS IFB IS AMENDED AS FOLLOWS:

INVITATION FOR BID NO. 100376

ARRA TUCSON HOUSE & CRAYCROFT TOWERS TOWER FILL AND CHILLER REPLACEMENT

AMENDMENT NO. TWO (2)

ITEM NO. ONE (1): BID DUE DATE:

Bid Due Date shall remain February 9, 2010 at 4:00 pm LOCAL AZ TIME.

ITEM NO TWO (2): PRE-BID CONFERENCE ATTENDEES:

Attached is a copy of the sign in sheet

ITEM NO THREE (3): CLARIFICATIONS:

Pursuant to the pre-bid conference held on January 28, 2010, the following is offered as clarification:

1. Mechanical Contractor shall include the addition of a pipe hanger for the chilled water supply riser from the penthouse mechanical room to the ceiling space of the third floor at Craycroft Towers.
2. W.E.S.T. Chemical is the current vender for chemical water treatment at Tucson House and Craycroft Towers.
3. All bidders shall provide a one-year maintenance contract with the two-year parts and labor warranty on the chiller per the bidding instructions.
4. The "Buy America" clause in the contract limits the potential bidders of the water-cooled chiller with the magnetic bearing, hermetic centrifugal compressors to McQuay and Multi-Stack.
5. Multi-Stack model #MS1201FS6W4H1-R134A is an approved alternate for bidding this project.
6. Carrier model 30HXC126 is not an approved alternate for bidding this project.

INVITATION FOR BID AMENDMENT

CITY OF TUCSON DEPARTMENT OF PROCUREMENT
255 W. ALAMEDA, 6TH FLOOR, TUCSON, AZ 85701
P.O. BOX 27210, TUCSON, AZ 85726
(520) 837-4126
ISSUE DATE: January 29, 2010

IFB NO.: 100376
IFB AMENDMENT NO.: Two (2)
PAGE 2 OF 2
IFB DUE DATE: 2/9/2010
CONTRACT OFFICER: Cherie Odeski

A SIGNED COPY OF THIS AMENDMENT MUST BE SUBMITTED WITH YOUR BID.
THIS IFB IS AMENDED AS FOLLOWS:

7. The replacement of the chiller at Craycroft Towers may be performed through the existing metal wall panels or existing metal roof panels. The installing contractor is responsible for replacing any wall or roof panel to match the existing penthouse construction. The installing contractor shall patch and repair the fire-proofing on the bottom side of the roof panels if the chiller is removed through the roof of the penthouse. Any damage to the existing roof or wall panels during the chiller replacement will be the responsibility of the installing contractor.

ALL OTHER PROVISIONS OF THE INVITATION FOR BID SHALL REMAIN IN THEIR ENTIRETY.

CONTRACTOR HEREBY ACKNOWLEDGES RECEIPT OF
AND UNDERSTANDING OF THE ABOVE AMENDMENT.

Signature Date


Printed Name and Title


Company Name

Address

City State Zip

THE ABOVE REFERENCED CONTRACT AMENDMENT
IS HEREBY EXECUTED THIS 29 DAY OF
January, 2010, AT TUCSON, ARIZONA.


for Mark A. Neihart, C.P.M., CPPB, A.P.P., CPM
Director of Procurement



**ATTENDENCE
PRE-BID CONFERENCE**

This is to acknowledge that the undersigned were present at City Hall, Attorney's 7th Floor Conference Room, Tucson, Arizona at 9:00 A.M., on Thursday, January 28, 2010 at the pre-bid conference for ARRA Tucson House & Craycroft Towers Tower Fill and Chiller Replacement, IFB 100376.

NAME OF PERSON	NAME OF FIRM	PHONE NUMBER	E-MAIL ADDRESS
FRANK ROESLER	ACS	520-696-1800	FlwRoesler@ACSHUAC.COM
Steve Hickam	Hickam Const.	(520) 408-5344	steve@hickamconstruction.com
DOUG SWAIM	CONDITIONED AIR MECH.	520-887-7700	Doug.Swaim@CSUSA.COM
Richard Vernick	SUNWESTERN CONSTRUCTION	520-294-8000	SWC@SunWesternConstruction.com
T Jeff Strong	LWC Service	520-666-4294	JEFF.STRONG@LWCService.com
Charles Amerise	ORACLE Control Systems	300.1712	Charles@HVACTucson.com
Nathan Koppeler	TBR	520 292 2225	nkappeler@tbrconstruction.net
Tessence Kelly	AMS	602 354 6396	TKelly@AMSofPhoenix.com
MAT VACCARO	HONEYWELL	480-286-3993	MATTHEW.VACCARO@HONEYWELL.COM
Joe Cesare	Centerline	520-449-1333	Joe.Cesare@yahoo.com
DAVID TYRRELL	Adams + Associates	(520) 323-3858	dyrrell@Adams-And-Assoc.com
Clifford Hanson	COT, HCD	(520) 791-4543	
Erin Cooper	COT HCD	(520) 791-4543	
George Selgado	COT/DFC	(520) 837-4122	
Tim Cortese	Madera Mechanical	(520) 629-0820	jcortese@maderamechanical.com
PAUL BLANK	RITENWAY VENTILATING CO.	(520) 247-5743	pblank@ritewayac.com
Claude Ralls	Sahara Mechanical	(520) 514-8200	Claude@SDL-Tucson.com
Wyndell HARRIS	Record Energy Concepts	520-740-0564	Wyndell@RECONDENERGYCONCEPTS.COM

Signed: Cheri Odeski
Cherie Odeski, CPPB, Senior Contract Officer

Handwritten signature